



## Final Checklist for Outbuildings

**These Items Must Be Fully Completed before Scheduling a Final inspection of your Outbuilding.**

### Exterior

Siding and soffit

Doors, both overhead and service

Light outside service door (if the structure has electric)

Foam covered on exterior of building (if foundation is insulated)

Grading (1/2 inch per 1 foot out 10 feet)

Erosion Control (site seeded or erosion control measures in place)

### Interior

Batt insulation secured with netting or faced insulation

Spray foam covered with sheetrock or other fire barrier

All outlets deviced or blank-plated and (working) light bulbs in sockets

All electrical must be GFCI protected

Electrical wires must be nail-plated if less than 1 ¼ inch from face of stud

Electrical wires running horizontally between stud cavities MUST be supported and stapled to a wood block

Separate ground rod required if more than one circuit on subpanel

Main disconnect and separate ground rod required if more than 6 circuits on subpanel