



Updated January 2023

Solar Array Final Inspection Checklist

- ☐ **Has your Electrical Service Certificate been uploaded?**
 - Be sure to have the correct form from the correct utility company
 - Be sure the form is filled out completely and signed by WI Licensed Master Electrician
 - The certificate should be uploaded on the All Croix website with the final inspection request. <https://www.allcroix.com/schedule-an-inspection>

 - ☐ **Are the Load Criteria/Engineering Specifications or Plans on-site?**

 - ☐ **Is there access to the electrical panel?**

 - ☐ **Are all grounding connections completed?**
 - ☐ **Panels and framework**
 - ☐ **Production meter**

 - ☐ **Are all the labels required by NEC 2017 in place?**
 - ☐ **Disconnect for meter socket**
 - ☐ **Electric panel**
-

PLEASE NOTE:

A fee will be assessed (\$110) for a scheduled inspection that is not ready (i.e., anything incomplete from this list is an automatic \$110 charge.)

Any electrical service certificate that is not accepted by the utility company (because it was filled out incorrectly, has missing/ incomplete information, or is rejected by the utility company for any other reason than the fault of the inspector) will result in an additional fee (\$110.)