


Grade



Electric: 18" in conduit  
24" direct burial

Gas: 12" minimum  
18" if subject to damage

- E Electric
- G Gas
- T Tracer wire